

Specification change of the ELECTRONIC MULTI-MEASURING INSTRUMENT

We would like to inform that we will change the firmware version and model code of the Electronic Multi-measuring instruments ME96SS Ver.B Series.

**1. Models**

ME96SSHB-MB(High-performance model), ME96SSRB-MB(Standard model)

**2. Before and after the change**

**2.1. Comparative table of high-performance model**

	Before	After
Model name	ME96SSHB-MB	(No change)
Model code	21N828	21N829
Firmware version	Ver.01.00	Ver.01.01
Connectable optional plug-in module *1	ME-4210-SS96B ME-0040C-SS96 ME-0052-SS96 ME-0000BU-SS96 ME-0000MT-SS96	ME-4210-SS96B ME-0040C-SS96 ME-0052-SS96 ME-0000BU-SS96 ME-0000MT-SS96 ME-0040MT2-SS96

**2.2. Comparative table of standard model**

	Before	After
Model name	ME96SSRB-MB	(No change)
Model code	21N827	(No change)
Firmware version *2	Ver.01.00	Ver.01.01
Connectable optional plug-in module *1	ME-4210-SS96B ME-0040C-SS96 ME-0052-SS96 ME-0000BU-SS96 ME-0000MT-SS96	(No change)

\*1. ME-0040MT2-SS96 is only applicable to ME96SSHB-MB with firmware version 01.01 or later. Not applicable to ME96SSRB-MB.

\*2. Since it has something in common with ME96SSHB-MB, ME96SSRB-MB also changes the firmware version.

**3. Reason for change**

Changed to apply to the newly released optional plug-in module model ME-0040MT2-SS96.

#### 4. How to check old and new

	The old version	The new version
Packing label (For ME96SSHB-MB)		

- "A" is Identification symbol.
- 21N828 and 21N829 are model codes.

	The old version	The new version
Serial number label (For ME96SSHB-MB)		

- 21N828 and 21N829 are model codes.

	The old version	The new version
Settings menu 4.2 (For ME96SSRB-MB and ME96SSHB-MB)		

- 01.00 and 01.01 are firmware version.

#### 5. Time of Change

From October, 2020.

(Please bear in mind that there may be a time lag due to the stock condition at the time of change)