

### Specification Change of Insulation Cap for CW Type Low-voltage Current Transformers

We would like to inform that we will change of insulation cap for CW Type low-voltage current transformers as below.

#### 1. Types

CW-M1, CW-M2, CW-M3

#### 2. Contents of change

In accordance with the Toxic Substances Control Act (TSCA), change the material to one that does not contain the following regulated materials.

- a. Decabromodiphenyl ether (DecaBDE)
- b. Phenol, isopropylated phosphate (3:1) (PIP (3:1))
- c. 2,4,6-tris(tert-butyl) phenol (2,4,6-TTBP)
- d. Pentachlorothiophenol (PCTP)
- e. Hexachlorobutadiene (HCBD)



※There is no change in function.

#### 3. Reason for change

For comply with the TSCA. regulation

#### 4. Identification Method

Please identify by the date on the packing bag name plate.

Before change	After change
 <p>Before 「21.9.30」 (30<sup>th</sup> September 2021)</p>	 <p>After 「21.10.1」 (1st October 2021)</p>

#### 5. Time of change

The change starts from production in October 2021.

(Please bear in mind that there may be a time lag due to the stock condition.)