

MITSUBISHI**GT16 Backlight for 10.4" GOT****User's Manual**

GT16-70VLTAA

Thank you for purchasing the GOT1000 Series.

Prior to use, please read both this manual and detailed manual thoroughly to fully understand the product.

MODEL	GT16-70VLTAA-U
MODEL CODE	1D7MF7
IB(NA)-0800484-A(1202)MEE	

GOT1000**ISAFETY PRECAUTIONS!**

(Always read these precautions before using this equipment.)

Before using this product, please read this manual and the relevant manuals introduced in this manual carefully and pay full attention to safety to handle the product correctly.

The precautions given in this manual are concerned with this product.

In this manual, the safety precautions are ranked as "DANGER" and "CAUTION".

DANGER Indicates that incorrect handling may cause hazardous conditions, resulting in death or severe injury.

CAUTION Indicates that incorrect handling may cause hazardous conditions, resulting in medium or slight personal injury or physical damage.

Note that the **CAUTION** level may lead to a serious accident according to the circumstances.

Always follow the precautions of both levels because they are important to personal safety.

Please save this manual to make it accessible when required and always forward it to the end user.

[BACKLIGHT REPLACEMENT PRECAUTIONS]**DANGER**

- Make sure to externally shut off all phases of GOT power supply (when GOT is connected via the bus type connection, make sure to shut off all phases of PLC CPU power supply as well) and remove the GOT from the control panel before backlight replacement.
- If all phases are not shut off, it may cause an electric shock.
- If backlight is replaced with the GOT on the control panel, the GOT may drop off, resulting in injuries.

CAUTION

- Make sure to wear gloves during backlight replacement. Failure to do so may cause injuries.
- Make sure to start the backlight replacement 5 or more minutes after power off of the GOT. Failure to do so may cause burn injuries as the old backlight holds heat for a while.

[STARTUP AND MAINTENANCE PRECAUTIONS]**CAUTION**

- Before handling the GOT, make sure to touch a grounded metal object to discharge the static electricity from the human body. Failure to do so may cause the GOT to fail or malfunction.

[DISPOSAL PRECAUTIONS]**CAUTION**

- Dispose of this product as industrial waste.

[TRANSPORTATION PRECAUTIONS]**CAUTION**

- Make sure to transport the GOT main unit and/or relevant unit(s) in the manner they will not be exposed to the impact exceeding the impact resistance described in the general specifications of the GT16 User's Manual, as they are precision devices. Failure to do so may cause the unit to fail. Check if the unit operates correctly after transportation.

Manuals

The following shows manuals relevant to this product.

Detailed Manual

Manual name	Manual number (Model code)
GT16 User's Manual(Hardware)((Sold separately))	SH-080928ENG (1D7MD3)

Relevant Manuals

For relevant manuals, refer to the PDF manuals stored in the CD-ROM for the drawing software used.

© 2012 MITSUBISHI ELECTRIC CORPORATION

Packing List

After unpacking the box, check that the following products are included.

Model	Product	Quantity
GT16-70VLTAA	Backlight	1

1. OVERVIEW

This User's Manual describes GT16 backlight for 12.1"/10.4" GOT (hereinafter referred to as the backlight). For applicable GOTs, refer to GT16 User's Manual.

Product	Model	Description	GOT
Backlight	GT16-70VLTAA	For 10.4" TFT (VGA) of high intensity and wide angle view	GT1675M-V*

*1 Function version D or later
For function version C or earlier, use the GT16-70VLTAA.**1.1 How to Check the Function Version and the Hardware Version**

Check the function version and the hardware version with the rating plate on the GOT rear face.



*1 Serial number
D820212216BS00048-D
Function version
Manufacture year and month
12 2
Manufacture year (Last two digits of the year)
Manufacture month (1 to 9: Manufacture month
X: October
Y: November
Z: December)

*2 Compatible backlight model

2. SPECIFICATIONS

The following shows the performance specifications of the backlight. The general specifications of the backlight are the same as those of the GOT.


For the general specifications of the GOT, refer to GT16 User's Manual.

Item	Specifications
	GT16-70VLTAA
Type	Cold cathode tube backlight
Life	50,000h or more (Operating ambient temperature: 25°C)
Weight	0.008kg (0.01lb)


3. BACKLIGHT REPLACEMENT**3.1 Preparing for Replacement**

The GOT includes the backlight for the liquid crystal display panel. The backlight intensity decreases with time. Replace the backlight when the display section becomes dark due to the decreased intensity and the picture is unclear. The following shows the procedures for replacing the backlight.

- Turn off the GOT.
- Disconnect the power supply cable and the communication cable. Remove the GOT from the control panel.
- Remove the right extension unit cover of the GOT. Remove an extension unit, including a bus connection unit, if it is mounted.



- Remove eight fixing screws on the GOT rear face with a screwdriver.


**3.2 Replacing Backlight**

The backlight replacement procedure differs according to the hardware version and the manufacture year and month of the GOT.


Model	GOT hardware version (Manufacture year and month)	Backlight replacement procedure
GT1675M-VTBA	A (January 2012) or earlier	Refer to 3.2.1
	B (February 2012) or later	Refer to 3.2.2
GT1675M-VTBD	B (January 2012) or earlier	Refer to 3.2.1
	C (February 2012) or later	Refer to 3.2.2

3.2.1 Backlight replacement procedure


- Remove the backlight cables and the relay cables from the GOT board connector. Since the relay connector adheres inside the GOT, detach the connector and perform the removal. (Expanded figure of part A in 3.1.4))




- Remove the backlight cables from the cable holder A by pulling the backlight cables one by one in the arrow I direction and then in the arrow II direction.




- Pull out the backlight so that the backlight does not hit the packing.




- Install a new backlight so that its top plate is inserted between the metal parts of the backlight replacement hole. When inserting a new backlight into the backlight replacement hole of the GOT, make sure not to damage the sheaths of the cables. Insert the backlight all the way in




- Connect the backlight cable connector to the GOT board connector. Do not put the cables of the backlight back to the cable holder A. Assemble the case in the reverse procedure of disassembly. (Tighten the fixing screws on the GOT rear face with a torque of 0.36 to 0.48 N·m). When installing the case, make sure that the cables are not stuck between the case and the GOT.




- Pull out the backlight so that the backlight does not hit the packing.



- Install a new backlight so that its top plate is inserted between the metal parts of the backlight replacement hole. When inserting a new backlight into the backlight replacement hole of the GOT, make sure not to damage the sheaths of the cables. Insert the backlight until you do not see its top plate.



- Connect the backlight cable connector to the GOT board connector. Secure the backlight cables with the cable holder B. Assemble the case in the reverse procedure of disassembly. (Tighten the fixing screws on the GOT rear face with a torque of 0.36 to 0.48 N·m). When installing the case, make sure that the cables are not stuck between the case and the GOT.



Warranty
Mitsubishi will not be held liable for damage caused by factors found not to be the cause of Mitsubishi; machine damage or lost profits caused by faults in the Mitsubishi products; damage, secondary damage, accident compensation caused by special factors unpredictable by Mitsubishi; damages to products other than Mitsubishi products; and to other duties.

△ For safe use

- This product has been manufactured as a general-purpose part for general industries, and has not been designed or manufactured to be incorporated in a device or system used in purposes related to human life.
- Before using the product for special purposes such as nuclear power, electric power, aerospace, medicine or passenger movement vehicles, consult with Mitsubishi.
- This product has been manufactured under strict quality control. However, when installing the product where major accidents or losses could occur if the product fails, install appropriate backup or fail-safe functions in the system.

Country/Region	Sales office/Te
U.S.A	Mitsubishi Electric Automation Inc. 500 Corporate Woods Parkway Vernon Hills, IL 60061, U.S.A. Tel : +1-847-223-2100
Brazil	MELCO S.A. P.R. Com.e Assessoria Técnica Ltda. Rua Correia Dias, 184, Edifício Paraiso Trade Center-8 andar Paraiso, São Paulo, SP Brazil Tel : +55-11-5908-8331
Germany	Mitsubishi Electric Europe B.V. German Branch Gothaer Strasse 8 D-40860 Ratingen, GERMANY Tel : +49-212-486-0
U.K.	Mitsubishi Electric Europe B.V. UK Branch Travelers Lane Hatfield, Hertfordshire, AL10 8XB, U.K. Tel : +44-1727-271000 Mitsubishi Electric Europe B.V. Italian Branch Centro Dir. Colleoni, Pal. Perseo-Ingr.2 Via Paracelso 12, I-20041 Agrate Brianza, Milano, Italy Tel : +39-039-60531
Italy	Mitsubishi Electric Europe B.V. Spanish Branch Carretera de Rubí 76-B, E-08190 Sant Cugat del Valles, Barcelona, Spain E-08190 Sant Cugat del Valles, Barcelona, Spain Tel : +34-93-565-3131
Spain	Mitsubishi Electric Europe B.V. French Branch 25, Boulevard des Bouvets, F-92741 Nanterre Cedex, France Tel : +33-1-556-5568
South Africa	Circuit Breaker Industries Ltd. Private Bag 2016, ZA-1600 Isando, South Africa Tel : +27-11-928-2000
Hong Kong	Mitsubishi Electric Automation (Hong Kong) Ltd. 10th Floor, Manulife Tower, 169 Electric Road, North Point, Hong Kong Tel : +852-2505-8900
China	Mitsubishi Electric Automation (China) Ltd. 4/F Zhi Fu Plaza, No.80 Xin Chang Road, Shanghai 200003, China Tel : +86-21-6120-0808
Taiwan	Setsuya Enterprise Co., Ltd. 6F No.105 Wu-Kung 3rd Rd., Wu-Ku Hsiang, Taipei Hsine, Taiwan Tel : +86-2-2229-2499
Korea	Mitsubishi Electric Automation Korea Co., Ltd. 1480-6, Cheong-dong, Gangseo-ku Seoul 157-200, Korea Tel : +82-2-3660-9552
Singapore	Mitsubishi Electric Asia Pte, Ltd. 307 Alexandra Road #05-01/02, Mitsubishi Electric Building, Singapore 159943
Thailand	Mitsubishi Electric Automation (Thailand) Co., Ltd. Baring Chai Estate No.111 Moo 4, Serithai Rd., T.Kharmrao, A.Kannayao, Bangkok 10230 Thailand Tel : +66-2-517-1326
Indonesia	P.T. Autokendindo Sumber Makmur Muara Karang Selatan, Block A/Jatara No.1 Kaw. No.11 Kawasan Industri Pergudangan Jakarta - Utara 14440, P.O.Box 5045 Jakarta, 11050 Indonesia Tel : +62-21-6630833 Messung Systems Pvt. Ltd. Electronics NO:III Unit No15, M.I.D.C Bhosari, Pune-411028, India Tel : +91-20-2712-3130
India	Mitsubishi Electric Australia Pty. Ltd. 348 Victoria Road, Rydalmere, N.S.W 2116, Australia Tel : +61-9684-7777
Australia	MITSUBISHI ELECTRIC CORPORATION HEAD OFFICE : TOKYO BUILDING, 2-