

**Notice of specification change of ACB**



We would like to inform you that we will change the specifications as follows.

**1. Types**

Low voltage air circuit breakers AE-SW electronic trip relay, power supply module  
P2 (DC24-60V, no alarm contact output) and P4 (DC24-60V, with alarm contact output)

**2. Content of the change**

Change the color of the wire connected to the P4 terminal (frame ground: FG) of the control  
circuit terminal.

	Before the change	After the change
Color	White	Yellow
spot		

**3. Reason for change**

To improve productivity.

**4. Time of change**

Production starting from February 2026.

(Please be noted that the time of change may be advanced or delayed.)