CERTIFICATE

Issued to: Applicant: Mitsubishi Electric Corporation Fukuyama Works 1-8 Midori-Machi Fukuyama-City Hiroshima-Pref 720 8647, Japan

Manufacturer: Mitsubishi Electric Dalian Industrial Products Co. Ltd. Dongbei 3-5 Dalian Economic & Technical Development Zone 116600 Dalian City Liaoning Prov., China Licensee: Mitsubishi Electric Corporation Fukuyama Works 1-8 Midori-Machi Fukuyama-City Hiroshima-Pref 720 8647, Japan

Product	:	Moulded-Case Circuit-Breaker
Trade name(s)	:	MITSUBISHI
Type(s)/model(s)	:	Moulded-Case Circuit-Breaker MITSUBISHI NF250-HXV, NF250-LXV and NF250-SXV

The product and any acceptable variation thereto is specified in the Annex to this certificate and the documents therein referred to.

DEKRA hereby declares that the above-mentioned product has been certified on the basis of:

- a type test according to the standard EN 60947-2:2006, EN 60947-2:2006/A1 2009 and EN 60947-2:2006/A2:2013
- an inspection of the production location according to CENELEC Operational Document CIG 021
- a certification agreement with the number 21/16095

DEKRA hereby grants/the right to use the KEMA-KEUR certification/mark

The KEMA-KEUR certification mark may be applied to the product as specified in this certificate for the duration of the KEMA-KEUR certification agreement and under the conditions of the KEMA-KEUR certification agreement.

This certificate is issued on 12 October 2017 and expires upon withdrawal of one of the above mentioned standards.

Certificate number: 33-101551

DEKRA Certification B.V.

drs. G.J. Zoetbrood Managing Director

© Integral publication of this certificate is allowed

ACCREDITED BY THE DUTCH ACCREDITATION COUNCIL



Rosa Zhou Certification Manager





DEKRA Certification B.V. Meander 1051, 6825 MJ Arnhem P.O. Box 5185, 6802 ED Arnhem, The Netherlands T +31 88 96 83000 F +31 88 96 83100 www.dekra-certification.com Company registration 09085396



SPECIFICATION OF THE CERTIFIED PRODUCT

Product data	
Product	: Moulded-Case Circuit-Breaker
Trade name(s)	: MITSUBISHI
Type(s)/model(s)	: NF250-HXV, NF250-LXV and NF250-SXV
Number of poles	: 2P, 3P, 4P (3P+ N, N without protection)
· · · · · · · · · · · · · · · · · · ·	: 2 or 3
	: 230 Vac / 380 Vac / 400 Vac / 415 Vac, 250 Vdc (2P in series)
0 ()	: 690 V : 8 kV
(Uimp)	. 0 KV
	: 40 °C
	: 100 A, 125 A, 150 A, 160 A, 175 A, 200 A, 225 A, 250 A
	: Equal to In
	: Equal to In
Current rating for four-pole circuit-	: Equal to In
breakers	
1 2	: 50 / 60 Hz
	: Suitable
	: A Magnetic time final
Instantaneous release	: Magnetic type, fixed,
	2 poles in series: 250 A: li = 12 In for AC
	250 A: II = 12.11 101 AC 250 A: II = 16,8 In for DC
	100 A - 225 A: li = 14 In for AC
	100 A - 225 A: li = 19,6 In for DC
	single pole:
	250 A: li = 18 In for AC
	250 A: li = 25,2 In for DC
	100 A - 225 A: li = 21 In for AC
	100 A - 225 A: li = 29,4 In for DC
	: Fixed
0	: Fixed
delay release Method of mounting	: Fixed
	: A and B
	: N/A
capacity (Isu)	
	: Yes (only for 2P, 3P),
capacity (lit)	4,5 kA at 415 Vac
Line/load terminal	: Immaterial
Connection	: Prepared copper conductor with cable lug
Dreduct data trms NE250 LIX/	
Product data – type NF250-HXV Rated ultimate short-circuit breaking	: 100 kA at 230 Vac,
capacity (Icu)	75 kA at 380 Vac, 400 Vac,
	70 kA at 415Vac.
	40 kA at 250 Vdc
Rated service short-circuit breaking	: 100% lcu
capacity (Ics)	
	: Left / Right: 60 mm
breaker)	Up / Down: 80 mm
	Front / Back: 160 mm



Product data – type NF250-LXV

Rated ultimate short-circuit breaking capacity (Icu) Rated service short-circuit breaking capacity (Ics) Safety distance (screen-circuit breaker)	 90 kA at 230 Vac, 50 kA at 380 Vac / 400 Vac / 415 Vac, 20 kA at 250 Vdc 100% Icu Left / Right: 60 mm Up / Down: 80 mm Front / Back: 160 mm
Product data – type NF250-SXV	
Rated ultimate short-circuit breaking capacity (Icu) Rated service short-circuit breaking	 85 kA at 230 Vac, 36 kA at 380 Vac / 400 Vac / 415 Vac, 20 kA at 250 Vdc 100% Icu

TESTS

Test requirements

EN 60947-2:2006 EN 60947-2:2006/A1:2009 EN 60947-2:2006/A2:2013

Test result

The test results are laid down in DEKRA test file 331241900.

Additional Information

The referred test reports are 3312419.50, 3306348.50 and also based on CQC CB test certificate CN24916 issued on 2012-12-04 with CQC CB test report C009-CB2012CQC-040514 issued on 2012-10-11.

The product also complies with IEC 60947-2:2006 + A1:2009 + A2:2013.

This certificate replaces certificate No. 3306348.02 which we herewith declare invalid.

Conclusion

The examination proved that all requirements were met.

Factory location

Mitsubishi Electric Dalian Industrial Products Co. Ltd. Dongbei 3-5 Dalian Economic & Technical Development Zone 116600 Dalian City Liaoning Prov., China