CERTIFICATE

Issued to: Applicant:

Mitsubishi Electric Corporation Fukuyama Works

1-8 Midori-Machi Fukuyama-City

Hiroshima-Pref 720 8647, Japan

Licensee:

Mitsubishi Electric Corporation Fukuyama Works

1-8 Midori-Machi Fukuyama-City

Hiroshima-Pref 720 8647, Japan

Product : Moulded-Case Circuit-Breaker Trade name(s) : MITSUBISHI ELECTRIC

Type(s)/model(s) : NF160-HGV, NF160-LGV and NF160-SGV

The product and any acceptable variation thereto is specified in the Annex to this certificate and the documents therein referred to.

DEKRA hereby declares that the above-mentioned product has been certified on the basis of:

- a type test according to the standard EN 60947-2:2006, EN 60947-2:2006/A1:2009 and EN 60947-2:2006/A2:2013
- an inspection of the production location according to CENELEC Operational Document CIG 021
- a certification agreement with the number 2116095

DEKRA hereby grants the right to use the KEMA-KEUR certification mark

The KEMA-KEUR certification mark may be applied to the product as specified in this certificate for the duration of the KEMA-KEUR certification agreement and under the conditions of the KEMA-KEUR certification agreement.

This certificate is issued on 4/April 2018 and expires upon withdrawal of one of the above mentioned standards.

Certificate number: 33-103330

DEKRA Certification B.V.

drs. G.J. Zoetbrood Managing Director Henk Schendstok Certification Manager

© Integral publication of this certificate is allowed

ACCREDITED BY THE DUTCH ACCREDITATION COUNCIL







SPECIFICATION OF THE CERTIFIED PRODUCT

Product data

Moulded-Case Circuit-Breaker Product Trade name(s) MITSUBISHI ELECTRIC

Type(s)/model(s) NF160-HGV, NF160-LGV and NF160-SGV

Number of poles 3P or 4P (N pole without protection)

Protected pole

Rated operational voltage (Ue) : 230 Vac, 380 Vac, 400 Vac, 415 Vac, 250 Vdc

Rated insulation voltage (Ui) : 690 V Rated impulse withstand voltage : 8 kV

(dmid)

: 40 °C Reference temperature (°C)

Rated tightening torque for terminals : 6 Nm for M8

(Nm)

Rated current (In) : 160 A Conventional thermal current (Ith) : Equal to In Current rating for four-pole circuit-: Equal to In

breakers

Rated frequency : 50 / 60 Hz Suitable for isolation Suitable

Utilization category : A

: Magnetic type, fixed, Instantaneous release

li = 10 In for 2 phases in series (AC) li = 15 In for single pole (AC) li = 14 In for 2 phases in series (DC) li = 21 In for single pole (DC)

Inverse time delay release : Thermal type, adjustable,

Ir = 125 A - 160 A

Time setting of the inverse time : Fixed

delay release

Method of mounting : Fixed EMC environment : A and B

Individual pole short-circuit breaking

: Yes (only suitable for 3P) capacity (lit) 15 In at 415 Vac Line/load terminal : Immaterial

Connection : Prepared copper conductor with cable lug

Product data - type NF160-HGV

Rated ultimate short-circuit breaking

capacity (Icu)

Rated service short-circuit breaking

capacity (Ics)

Safety distance (screen-circuit

breaker)

: 100 kA at 230 Vac, 75 kA at 380 / 400 Vac,

70 kA at 415 Vac. 40 kA at 250 Vdc

: 100% lcu

: Left / Right: 60 mm Up / Down: 80 mm Front / Back: 160 mm

Product data – type NF160-LGV

Rated ultimate short-circuit breaking

capacity (Icu)

Rated service short-circuit breaking

capacity (Ics)

Safety distance (screen-circuit

breaker)

: 90 kA at 230 Vac, 50 kA at 380 / 400 / 415 Vac,

20 kA at 250 Vdc

: 100% Icu

: Left / Right: 60 mm

Up / Down: 80 mm Front / Back: 160 mm







Product data – type NF160-SGV

Rated ultimate short-circuit breaking

capacity (Icu)

Rated service short-circuit breaking

capacity (Ics)

Safety distance (screen-circuit

breaker)

: 85 kA at 230 Vac, 36 kA at 380 / 400 / 415 Vac,

20 kA at 250 Vdc

: 100% lcu

: Left / Right: 50 mm Up / Down: 70 mm

Front / Back: 160 mm

TESTS

Test requirements

EN 60947-2:2006 EN 60947-2:2006/A1:2009 EN 60947-2:2006/A2:2013

Test result

The test results are laid down in DEKRA test file 331338500.

Additional information

This certificate is based on certificate no. 3310628.02 issued on 17 January 2017.

The referred test reports are 3313385.50, 3310628.50, 3302725.50 and also based on CQC CB test certificate CN20815 issued on 2011-07-05 with CQC CB test report C009-CB2010CQC-028669 issued on 2011-05-18.

The product also complies with IEC 60947-2:2006 + A1:2009 + A2:2013.

This certificate replaces certificate No. 33-102741 which we herewith declare invalid.

Conclusion

The examination proved that all requirements were met.

Factory location

Mitsubishi Electric Dalian Industrial Products Co., Ltd. Dongbei 3-5, Dalian Economic & Technical Development Zone, 116600 Liaoning Province, China