CERTIFICATE

Issued to: Applicant:

Mitsubishi Electric Low Voltage Equipment (Xiamen)Co., Ltd

2nd Floor, No.122-126(double), Yinghao Road Jimei District

361021 Xiamen City, Fujian Province, China

Licensee:

Mitsubishi Electric Low Voltage Equipment (Xiamen)Co., Ltd

2nd Floor, No.122-126(double), Yinghao Road

Jimei District

361021 Xiamen City, Fujian Province, China

Product : Moulded-Case Circuit-Breaker

Trade name(s) : MITSUBISHI

Type(s)/model(s) : NFC100-CMXA and NFC100-SMXA

The product and any acceptable variation thereto is specified in the Annex to this certificate and the documents therein referred to.

DEKRA hereby declares that the above-mentioned product has been certified on the basis of:

- a type test according to the standard EN 60947-2:2006, EN 60947-2:2006/A1:2009/and EN 60947-2:2006/A2:2013
- an inspection of the production location according to CENELEC Operational Document CIG 021
- a certification agreement with the number 2185553

DEKRA hereby grants the right to use the KEMA-KEUR certification mark

The KEMA-KEUR certification mark may be applied to the product as specified in this certificate for the duration of the KEMA-KEUR certification agreement and under the conditions of the KEMA-KEUR certification agreement.

This certificate is issued on 31 May 2018 and expires upon withdrawal of one of the above mentioned standards.

Certificate number: 33-104128

DEKRA Certification B.V.

drs. G.J. Zoetbrood Managing Director Henk Barends Certification Manager

© Integral publication of this certificate is allowed

ACCREDITED BY THE DUTCH ACCREDITATION COUNCIL







SPECIFICATION OF THE CERTIFIED PRODUCT

Product data

Product Moulded-Case Circuit-Breaker

Trade name(s) **MITSUBISHI**

Type(s)/model(s) : NFC100-CMXA and NFC100-SMXA

Protected pole : 2 or 3

Rated operational voltage (Ue) : 415 Vac, 400 Vac, 380 Vac, 230 Vac

Rated insulation voltage (Ui) : 690 V Rated impulse withstand voltage : 8 kV

(Uimp)

Reference temperature (°C) : 40 °C

Rated tightening torque for terminals : 15 A - 50 A: 2,0 Nm for M5

60 A - 100 A: 6,0 Nm for M8

Rated current (In) : 15 A, 16 A, 20 A, 25 A, 30 A, 32 A, 40 A, 50 A, 60 A,

63 A, 75 A, 80 A, 100 A

Equal to In Conventional thermal current (Ith) 50 / 60 Hz Rated frequency Suitable for isolation Suitable

Utilization category : A : Left / Right: 20 mm, Up / Down: 60 mm, Front / Back: 0 mm

Safety distance (screen-circuit

breaker)

Instantaneous release : Magnetic type, fixed,

> 15 A - 32 A: li = 500 A for 2 phases in series 40 A - 100 A: li = 10 In for 2 phases in series

1,2 li for single pole

Time setting of the instantaneous

: Thermal type, fixed

: Fixed

Inverse time delay release Time setting of the inverse time Fixed

delay release

2In tripping time declared by the manufacturer:

15 A - 32 A: 30 s ≤ t ≤ 180 s 40 A - 100 A: $60 \text{ s} \le \text{t} \le 360 \text{ s}$

Method of mounting : Fixed **EMC** environment : A and B

Individual pole short-circuit breaking

capacity (lit)

Only suitable for 2P and 3P 15 A - 32A: 720 A at 415 Vac, 40 A - 100 A: 15 In at 415 Vac

Line/load terminal : LINE and LOAD are marked

Connection : Prepared copper conductor with cable lug

Product data – type NFC100-CMXA

Rated ultimate short-circuit breaking : 10 kA at 415 Vac / 400 Vac.

capacity (Icu) 15 kA at 380 Vac.

25 kA at 230 Vac

Rated service short-circuit breaking : 5 kA at 415 Vac / 400 Vac,

7,5 kA at 380 Vac. capacity (Ics) 12,5 kA at 230 Vac

Number of poles : 2P and 3P

Product data – type NFC100-SMXA

Rated ultimate short-circuit breaking : 25 kA at 415 Vac / 400 Vac.

capacity (Icu) 30 kA at 380 Vac.

50 kA at 230 Vac

Rated service short-circuit breaking

capacity (Ics)

: 12,5 kA at 415 Vac / 400 Vac,

15 kA at 380 Vac. 25 kA at 230 Vac



page 2 of 2



Number of poles : 2P, 3P, 4P (N pole without protection)

Current rating for four-pole circuit-

breakers

: Equal to In

TESTS

Test requirements

EN 60947-2:2006 EN 60947-2:2006/A1:2009 EN 60947-2:2006/A2:2013

Test result

The test results are laid down in DEKRA test file 331368500.

Additional information

The referred test reports are 3307577.50 and 3313685.50. This certificate is based on KEMA KEUR certificate 3307577.01 issued on 2015-12-07.

The product also complies with IEC 60947-2:2006 + A1:2009 + A2:2013.

Conclusion

The examination proved that all requirements were met.

Factory location

Mitsubishi Electric Low Voltage Equipment (Xiamen)Co., Ltd 2nd Floor, No.122-126(double), Yinghao Road Jimei District 361021 Xiamen City, Fujian Province, China